



Leino Park Water District
52 Old Oak Ave., Westminister, MA 01473
www.LeinoPark.org lpwd@LeinoPark.org

2025 Consumer Confidence Report

Leino Park Water District, Westminister, MA

MASSDEP Public Water Supply (PWS) ID # 2332005

Leino Park's water is supplied by the Westminister Water Department (PWS2332000) which buys its water from the City of Fitchburg (PSW2097000). We do not filter or add anything to the water we purchase. In addition to the water quality testing done by Fitchburg and Westminister, the Mass Department of Environmental Protection (DEP) requires that Leino Park Water District (LPWD) test for bacteria, chlorine, copper, lead, iron, manganese, and disinfection byproducts within its distribution system. The water quality information presented in the tables below is from 2025 or from the most recent round of testing in accordance with regulations. Only the detected contaminants are shown. The Westminister Water Department has published their 2025 Annual Drinking Water Quality Report, which includes their monitoring results and explanation of the terms used in this report. Please find it online at: <https://www.westminister-ma.gov/2025CCR>

WATER QUALITY DATA TABLES

Bacteria	Date Collected	Highest # Positive Samples in a Month	MCL	MCLG	Violation (Y/N)	Possible Sources
Total Coliform	2 Samples per Month	0	1	0	N	Human and animal fecal waste

Lead and Copper	Date Collected	90 th Percentile *	Action Level (AL)	MCLG	# of Sites Sampled	# of Sites above AL	Exceeds AL (Y/N)	Possible Sources
Lead (ppb)	8/8/23	5.35	15	0	5	0	N	Corrosion of household plumbing systems; Erosion of natural deposits
Copper (ppm)	8/8/23	.152	1.3	1.3	5	0	N	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives

* The 90th percentile for Leino Park was calculated by averaging the two highest results from the five homes that were sampled. The 90th percentile value was then compared to the Action Level to determine compliance.

Disinfectants and Disinfection By-Products	Date(s) Collected	Highest RAA*	Range Detected	MCL or MRDL	MCLG or MRDLG	Violation (Y/N)	Possible Sources
Haloacetic Acids (HAA5) (ppb)	Quarterly	40	31-52	60	N/A	N	Byproduct of drinking water disinfection
Total Trihalomethanes (TTHMs) (ppb)	Quarterly	78	61-85	80	N/A	N	Byproduct of drinking water chlorination
Total Chlorine (ppm)	2 Samples per Month	.59	0.12-1.12	4.0	4.0	N	Water additive used to control microbes

* The highest running annual average (RAA) is the highest average of four consecutive quarterly readings, or the highest average of 12 consecutive monthly readings.

Our testing found that the Leino Park Water District was in full compliance of drinking water standards for all tested contaminants for the entire year, including Total Trihalomethanes (TTHMs), which flagged violations for 3 of 4 quarters in 2024. Leino Park Water District worked with the Town of Westminster to come up with and implement an aggressive plan of flushing our water system. We flushed over 144 thousand gallons of water in 2025. We will continue to work with the Town of Westminster to do what ever is necessary to keep our water safe for our customers.

Unregulated and Secondary Contaminants	Date Collected	Detected Amount	Average	SMCL	ORSG	Possible Sources
Iron (ppb)	5/20/2025	31	--	300	N/A	Naturally occurring, corrosion of cast iron pipes
Manganese (ppb)	5/20/2025	<0.010	--	50	Health Advisory of 300	Natural sources as well as discharges from industrial uses

In October 2024, the Leino Park Water District submitted a Service Line Inventory (SLI) to the DEP showing that all connections to our customers are lead free. Our submission was approved in September 2025. Our non-lead service line statement (nonLSL) is posted on our website at: https://leinopark.org/docs/LPWD_NonLSL_Statement2024-11-25.pdf. The SLI is also available for viewing on our website.

Our water system is routinely inspected by the Massachusetts Department of Environmental Protection (MassDEP). MassDEP inspects our system for its technical, financial, and managerial capacity to provide safe drinking water to you. This inspection is called a Sanitary Survey and is typically held every 2 years. In July 2025 we received the results of our latest inspection held in February, revealing a deficiency for not having “a written maintenance program in place.” There were no violations, recommendations, or other deficiencies. We responded to MassDEP with a proposed maintenance plan by the end of July to close the deficiency and have heard nothing since. The Leino Park Water District Water System Maintenance Plan specifies how often we exercise all the valves, hydrants, and curb stops in our system. The plan may be found on our website under the ‘News and Information’ tab.

The Leino Park Water District consumed 1,830,043 gallons of water in 2025. Please conserve water inside and outside your homes. This includes watering lawns only when needed, ideally early in the morning or after the sun goes down.

Public Water System Information

Mailing address: 52 Old Oak Ave, Westminster, MA 01473

Contact person: Derek Knerr - Water System Operator

Phone: 978-874-1036

email: DerekK@LeinoPark.org or LPWD@LeinoPark.org

Website: <https://www.leinopark.org>

For questions, concerns, or additional copies of this report, contact our Water System Operator or any of the Leino Park Water District Commissioners:

Robert Brown @ 978-874-0408 Robert Marien @ 978-874-5417 Josef Monette @ 978-906-4629

The Leino Park Water District Board of Commissioners meetings are scheduled at 7:00 PM on the first Wednesday of every month. Meetings are held at **11 Old Oak Ave. The Public is invited.** Visit www.leinopark.org to view minutes of past meetings or the latest information about our next meeting.

Our Annual District Meeting is scheduled for **10:00 AM June 27, 2026 at 46 Old Oak Ave.** Residents are urged to attend.